NOTICE TO THE PUBLIC

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

The Town of Angier Has Levels of Total Trihalomethanes (TTHMs) Above Drinking Water Standards

Trihalomethanes (THM) are a group of four chemicals that are formed along with other disinfection by products when chlorine or other disinfectants used to control microbial contaminants in drinking water react with naturally occurring organic and inorganic matter in water.

Our water system recently violated a drinking water standard. Although this is not an emergency however, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. The latest test results we received on March 2011 show that our system exceeds the standard or maximum contaminant level (MCL) for Total Trihalomethanes (TTHMs). The standard for TTHMs is 0.080 milligrams per liter (mg/L). The average level of TTHMs for the last 12 months was .081 mg/L.

What should I do?

You do not need to use an alternative (e.g., bottled) water supply. However, if you have specific health concerns, consult your doctor.

What does this mean?

This is not an immediate risk. If it had been, you would have been notified immediately. However, ***some people who drink the water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.***

What happened? What is being done? When will the problem be corrected?

Our March samples were above the MCL allowable limits. These results put us over our 12 month running average. In June samples were taken and the results were below the Allowable limits, but not below the 12 month running average

We are working with Harnett County to evaluate the water supply and researching options to correct the problem. These options may include treating the water to remove trihalomethanes or extensive flushing of the water system.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information, please contact:

Responsible Person Emory Brooks	System Name **Town of Angier**	System Address (Street) 55 North Broad St. West Angier, NC 27501
Phone Number 919-639-2071	System PWSID # 03-43-015	System Address (City, State, Zip) PO Box 278 Angier, NC 27501

Violation Awareness Date: June 20, 2011

Date Notice Distributed: July 7, 2011 **Method of Distribution Bulk Mail**

Public Notification Certification:

The public water system named above hereby affirms that public notification has been provided to its consumer in accordance with all delivery, content, format, and deadline requirements specified in 15A NCAC 18C .1523.

Owner/Operator: Coley B. Price (Signature) Coley B. Price (Print Name) 6-30-11 (Date)